




BUILDING 1—THIRD FLOOR

- NOTE:
- 1. ALL ROUND DUCT SHOWN IS FOR AREA REFERENCE ONLY. DUCT CAN BE RECTANGULAR OF EQUAL AREA.
 - 2. ALL WORK TO BE COMPLETED WITHIN THE CONSTRUCTION PHASE. THE SYSTEM MUST BE ABLE TO CONTINUE TO PROVIDE THE CORRECT AIR CHANGES TO THE COMPLETED PHASE(S) WHILE THE NEXT PHASE IS IN CONSTRUCTION.
 - 3. ALL WORK TO BE COMPLETED OFF-HOURS.

NO.		DATE	DESCRIPTION
REVISIONS			
SHEET TITLE			
HVAC WORK LAYOUT			
BLDG. NO.		PROJECT TITLE	
1		RENOVATE B-1C SPECIALTY CLINICS	
DRAWN		CHECKED	DATE
BRM			12/2011
APPROVED			DRAWING NUMBER
CHIEF, ENGINEERING SERVICE			2949
APPROVED			DWG. 1 OF 1
DIRECTOR, VAMC, CANANDAIGUA			PROJECT NUMBER
			528A5-12-504
V.A. MEDICAL CENTER			
LOCATION			
CANANDAIGUA, NY 14424			